

Number	89282/01	Replaces	--
Issued	27-08-2015	Scope	2009/142/EC 92/42/EEC
Report number	150401784		
PIN	0063CQ3784	Contract number	E 8090

EC TYPE EXAMINATION CERTIFICATE

Kiwa hereby declares that the **Low Temperature Central Heating Boilers**, types

**ThemaClassic C25 (H-HU), ThemaClassic C25 (H-PL),
ThemaClassic C25 (H-UA), ThemaClassic C25 (H-FR),
ThemaClassic V25 (H-FR), ThemaClassic C25 (H-VE-EU)**

Supplied by **Saunier Duval**
44315 Nantes cedex, France

meet the essential requirements as described in the
Directive 2009/142/EC relating to appliances burning gaseous fuels and the
Directive 92/42/EEC on efficiency requirements.


Country of destination, appliance categories, installation types and available types
are mentioned in the appendix to this certificate.



Bouke Meekma
Kiwa

kiwa
Approved

EC Directive



2009/142/EC
92/42/EEC

G A S T E C



0063

0063
Page 1 of 1

CERTIFICATE 89282/01

Appendix no.: 1
Dated: August-2015
Examination report(s): 150401784

List of available types,

Type name	Appliance type	Heat input (kW)
ThemaClassic C25 (H-HU)	B11BS	10.5 - 26.7
ThemaClassic C25 (H-PL)	B11BS	10.5 - 26.7
ThemaClassic C25 (H-UA)	B11BS	10.5 - 26.7
ThemaClassic C25 (H-FR)	B11BS	10.5 - 26.7
ThemaClassic V25 (H-FR)	B11BS	10.5 - 26.7
ThemaClassic C25 (H-VE-EU)	B11BS	10.5 - 26.7

Directives

Gas Appliance Directive (2009/142/EC)
Boiler Efficiency Directive (92/42/EEC)

Standard

EN 15502-1:2012, EN 15502-2-2: 2014

Appliance category

I12HS3B/P G20 - 25mbar, G25.1 – 25mbar, G30/G31 - 30mbar
I12ELwLs3B/P G20 - 20mbar, G27 – 20mbar, G2.350 – 13mbar, G30/G31 - 37mbar
I12H3B/P G20 - 20mbar, G30/G31 - 30mbar
I12E+3+ G20/G25 - 20mbar/25mbar, G30/G31 - 28-30mbar/37mbar
I12H3B/P G20 - 20mbar, G30/G31 - 30mbar
I12H3+ G20 - 20mbar, G30/G31 - 28-30mbar/37mbar

Countries of destination

Hungary (HU), Poland (PL), Ukraine (UA), France (FR), Bulgaria (BG),
Estonia (EE), Greece (GR), Latvia (LV), Lithuania (LT), Portugal (PT)